



FAX : 0135-2675408 E-mail : semchddn@gmail.com
OFFICE OF THE SUPERINTENDING ENGINEER,
MECHANICAL CIRCLE,
UTTARAKHAND PEYJAL SANSADHAN AVAM NIRMAN NIGAM
DEHRADUN-248001 (UTTARAKHAND)

No. / E - NIVIDA / Dated

Corrigendum

In reference to the letter no. 5103/E-Nivida/258, dated 19.12.2018 of this office, the pre bid meeting held on dated 04.01.2019 at 04:00 pm, the representatives of three firms namely 1. M/s Simplex Control Equipments Co, Haridwar (2) M/s Cimcon Software (I.) Pvt. Ltd., Dehradun & (3) M/s R.K. Engineers Sales, Lucknow were present. The queries raised by M/s Simplex Control Equipments Co, Haridwar are classified as under :-

S.No.	Queries raised by M/s Simplex Control Equipments Co, Haridwar	Ammendments
1.	<u>Point no. 1</u>	To intergrate the data of new automated tubewell stations the department will provide the data string. The MCS software is pre-configured to add new automated tubewells. Manual for operation & configuration will be provided.
2.	<u>Point no. 2</u>	Redundancy as mentioned in technical specifications is required for CPU and power supply. In both cases, if there is failure of Master, the slave should automatically 'take over' without disrupting the operations.
3.	<u>Point 2(1)</u>	The bidder is free to inspect the sites and take note of the electrical panels and related equipments.
4.	<u>Point 2(2)</u>	All automation hardware & instrumentation should be CE/UL certified
5.	<u>Point 2(3)</u>	It is necessary for the bidder to qualify for both tubewell pumping stations and pumping plant. The prequalification criteria remains the same as mentioned in tender, this cannot be bifurcated and diluted.
6.	<u>Point 2(4)</u>	The tender specifies clearly that high head schemes are to be automated and so all automation hardware and instruments have to be suitable for high head pumping stations wherin the head varies from 300 mtr. to 600 mtr. The bidder should take note of this.
7.	<u>Point 2(5)</u>	The date of the tender cannot be extended.

In addition to the above Sl. No. 2.03 and 17 of BOQ is modified as per requirement and the tender value mistakenly entered INR 2,50,000.00 is ammended as INR 100,00,000.00 (Projected amount of annual work).

Endt. No. 53 / E-NIVIDA / 06 Dated 05-01-2019

Copy forwarded to the following for information and necessary action :-

1. Managing Director, Uttarakhand Peyjal Nigam, Dehradun.
2. Chief Engineer (HQ.), Uttarakhand Peyjal Nigam, Dehradun.
3. Chief Engineer (Garhwal/Kumaon), Uttarakhand Peyjal Nigam, Pauri/Haldwani.
4. Superintending Engineer, Mechanical Circle, Uttarkhand Peyjal Nigam, Haldwani.
5. Executive Engineer, (HQ.), Head Office, Uttarakhand Peyjal Nigam, Dehradun for publishing the above e-tender notice on Departmental website (www.peyjal.uk.gov.in)
6. Executive Engineer, Mechanical Division, Uttarakhand Peyjal Nigam, Dehradun/Kotdwar/Haldwani/Almora.

मुख्य अभि. (मुं.)
11/1/19

Superintending Engineer